

December 2021 Solicitation Questions and Responses

Solicitation	Project	Question	Response
SE-01	2430-07-00	Please elaborate on the specific repairs needed for retaining walls R-51-80 and R-51-81.	The radius sections at 3354 & 3340 124th Street need to be repaired; structure plans are required. If rebuilding the wall with existing block does not meet structural requirements, removing and redesigning a portion of the wall may be needed.