

## July 2026 Solicitation Questions and Responses

| Solicitation | Project    | Question                                                                                                                                                                  | Response                                                                                                                               |
|--------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------|
| NC-03        | 9215-01-05 | Are curb & gutter, sidewalk, and ADA ramp replacements anticipated as part of this project?                                                                               | Upgrading all curb ramps to ADA standards and spot curb repair are anticipated. Sidewalk replacement is not anticipated.               |
| NC-04        | 9231-08-02 | Is an archaeological survey and architecture history survey anticipated?                                                                                                  | Full surveys are not anticipated since all work is anticipated within existing disturbed lands. Coordination with THPO is anticipated. |
| NE-01        | 1500-13-00 | Will the department provide aerial mapping and survey?                                                                                                                    | WisDOT will provide high resolution ortho and lidar with delivery schedule of February 2027                                            |
| NE-03        | 9560-08-00 | Are curb ramp replacements for ADA compliance anticipated?                                                                                                                | Curb ramp upgrades to ADA standards are anticipated.                                                                                   |
| NW-01        | 7050-00-05 | It appears that there is badly deteriorated curb and gutter within the project limits; will there be full or spot replacement of curb and gutter included in the project? | Approximately 1100' of curb and gutter replacement on the east side of STH 73 in the community of Christie is anticipated.             |
| SE-01        | 1067-02-09 | Please verify the schedule which shows one year from 30% to PS&E. Also shows start date of 9/1/26 which is only 3 weeks from posting selections.                          | The anticipated schedule is correct. Changes may be made as part of negotiations.                                                      |