

- A. The installing contractor shall install the parallel SPD with short and straight conductors as practically possible. The contractor shall twist the SPD input conductors together to reduce input conductor inductance. The contractor shall follow the SPD manufacturer's recommended installation practices as found in the installation, operation and maintenance manual and comply with all applicable codes.

These Guide Specifications comply with the outlines of the Construction Specification Institute per CSI MP-2-2-85 and MP-2-1-88

END OF SECTION