

GENERAL NOTES

DRAWINGS SHALL NOT BE SCALED.

THE PLAN QUANTITY FOR THE BID ITEM (INSERT WALL SYSTEM) IS BASED ON A WALL HEIGHT MEASURED FROM THE TOP OF WALL TO A CONSTANT DEPTH OF (INSERT VALUE) BELOW FINISHED GRADE.

DESIGN DATA

THE CONTRACTOR SHALL PROVIDE COMPLETE DESIGN, PLANS, DETAILS, SPECIFICATIONS, AND SHOP DRAWINGS FOR THE RETAINING WALLS IN ACCORDANCE WITH THE SPECIAL PROVISIONS. THE RETAINING WALL MANUFACTURER SHALL PROVIDE TECHNICAL ASSISTANCE TO THE CONTRACTOR DURING CONSTRUCTION. THE COST OF FURNISHING THESE ITEMS SHALL BE INCLUDED IN THE BID ITEM ("INSERT WALL SYSTEM OR SYSTEMS").

PLANS, ELEVATIONS AND DETAILS SHOWN ON THESE DRAWINGS ARE INTENDED TO INDICATE WALL LOCATIONS, LENGTHS, HEIGHTS, AND DETAILS COMMON TO THE WALL SYSTEM SELECTED. THE CONTRACTOR SHALL VERIFY THAT THE WALL SYSTEM SELECTED WILL CONFORM TO THE REQUIRED ALIGNMENTS AND DETAILS.

THE RETAINING WALL IS TO BE DESIGNED USING THE ELEVATIONS GIVEN ON THIS SHEET.

DESIGN FOR RETAINING WALL TO PROVIDE FOR FINISHED GRADE SLOPED BEHIND WALL AS SHOWN.

DESIGN RETAINING WALL FOR A LIVE LOAD SURCHARGE OF (INSERT VALUE).

THE MAXIMUM VALUE OF THE ANGLE OF INTERNAL FRICTION OF THE WALL BACKFILL MATERIAL IN THE REINFORCED ZONE SHALL BE ASSUMED TO BE 30° WITHOUT CERTIFIED TEST VALUES.

DESIGNER NOTES

THE LENGTHS PROVIDED IN THE TABLE ARE THE MINIMUM REQUIRED REINFORCEMENT LENGTHS BASED UPON THE MINIMUM DESCRIBED IN THE WALL SYSTEM SPECIAL PROVISIONS OR EXTERNAL AND OVERALL STABILITY AT THE DESIGNATED LOCATIONS. THESE DESIGNATED LOCATIONS REPRESENT TYPICAL AND CRITICAL WALL LOCATIONS, BUT SHALL NOT BE CONSIDERED ALL INCLUSIVE. THE CONTRACTOR DESIGN LENGTHS SHALL MEET OR EXCEED THE MINIMUM VALUES REPRESENTED IN THE TABLE AT THESE DESIGNATED LOCATIONS.



THE LENGTHS PROVIDED IN THE TABLE ARE THE MINIMUM REQUIRED REINFORCEMENT LENGTHS BASED ON OVERALL STABILITY PERFORMED BY THE WALL DESIGNER. COMPOUND STABILITY IS THE CONTRACTOR'S RESPONSIBILITY.

MINIMUM EMBEDMENT BASED ON SITE SPECIFIC PARAMETERS (1'-6" MINIMUM FOR ALL WALLS ON LEVEL GROUND). FIELD EMBEDMENTS SHALL MEET OR EXCEED THE MINIMUM EMBEDMENTS. FIELD EMBEDMENTS BELOW MINIMUM EMBEDMENT SHALL NOT BE INCLUDED IN THE PAY LIMITS.

STRATUM LOCATIONS & SOIL DESCRIPTIONS AT EACH BORING LOCATION.

NOMINAL MSE PANEL DIMENSIONS ARE 5-FOOT HIGH AND 5 TO 10 FOOT WIDE. THE WALL DESIGNER SHALL PROVIDE DETAILS BASED ON NOMINAL PANEL DIMENSIONS AND CONFIGURATION. DETAILS SHALL BE ABLE TO ACCOMMODATE VARIOUS PANEL DIMENSIONS. THE CONTRACTOR AND WALL SUPPLIER SHALL COORDINATE DETAILS BASED ON THE ACTUAL DIMENSIONS.

LOCATE NAME PLATE ON THE FRONT OF WALL APPROXIMATELY 3' TO 6' HIGH. CENTER NAME PLATE BETWEEN CAST-IN-PLACE CONCRETE COPING JOINTS, CENTERED ON A NON-CAP BLOCK, OR AS DIRECTED BY THE FIELD ENGINEER



WALL EXTERNAL & OVERALL STABILITY EVALUATION

DIMENSIONS	EVALUATED LOCATIONS
WALL HEIGHT (FEET)	
EXPOSED WALL HEIGHT (FEET)	
MINIMUM LENGTH OF REINFORCEMENT (FEET)	☑
WALL STATION	
BORING USED	
CAPACITY TO DEMAND RATIO (CDR)	
SLIDING (CDR>1.0)	
ECCENTRICITY (CDR>1.0)	
OVERALL STABILITY (CDR>1.0)	☆
BEARING RESISTANCE (CDR>1.0)	
FACTORED BEARING RESISTANCE (PSF)	

GEOMETRY TABLE

WALL STATION	ROADWAY STATION	OFFSET TO F.F. WALL	TOP OF WALL ELEV.	FINISHED GRADE ELEV.

SOIL PARAMETERS

STRATUM LOCATIONS & SOIL DESCRIPTIONS	TOTAL UNIT WEIGHT (PCF)	FRICTION ANGLE (DEGREES)	COHESION (PCF)
GRANULAR BACKFILL (REINFORCING ZONE OR BACKFILL)			
(INSERT SOIL TYPE) RETAINED SOIL *			
(INSERT SOIL TYPE) FILL			
EL. --- EL. ---			
(INSERT SOIL TYPE)			
EL. --- EL. ---			
(INSERT SOIL TYPE)			
EL. --- EL. ---			

* DESIGN WALL FOR THESE VALUES

LIST OF DRAWINGS

1. (INSERT WALL SYSTEM)
2. SUBSURFACE EXPLORATION

LRFD PROPRIETARY RETAINING WALLS (GENERAL PLAN)



APPROVED: *Laura Shadewald*

DATE: 7-23