



† SURVEY TYPE: \_\_\_\_\_  
 SURVEY COMPLETED DATE: \_\_/\_\_/\_\_\_\_

**TOTAL ESTIMATED QUANTITIES**

BID ITEM NUMBER	BID ITEMS	UNIT	TOTAL
502.3200	PROTECTIVE SURFACE TREATMENT	SY	
509.0301	PREPARATION DECKS TYPE 1	SY	
509.0302	PREPARATION DECKS TYPE 2	SY	
509.0500	CLEANING DECKS	SY	
509.2000	FULL-DEPTH DECK REPAIR	SY	
509.2500	CONCRETE MASONRY OVERLAY DECKS	CY	
POSSIBLE ADDITIONAL BID ITEMS			
502.3210	PIGMENTED SURFACE SEALER	SY	
* 509.0505.S	CLEANING DECKS TO REAPPLY CONCRETE MASONRY OVERLAY	SY	
* 509.9005.S	REMOVING CONCRETE MASONRY DECK OVERLAY (STRUCTURE)	SY	
514.0900	ADJUSTING FLOOR DRAINS	EACH	

THIS IS A PARTIAL LIST OF POSSIBLE BID ITEMS. BID ITEMS MAY NEED TO BE ADDED OR REMOVED TO FIT EACH INDIVIDUAL CASE.

**DESIGN DATA**

LIVE LOAD:  
 INVENTORY RATING: HS-\_\_  
 OPERATING RATING: HS-\_\_  
 WISCONSIN STANDARD PERMIT VEHICLE (WIS-SPV) = \_\_ \_\_ \_\_ KIPS

MATERIAL PROPERTIES:  
 CONCRETE MASONRY OVERLAY DECKS  $f_c = 4,000$  P.S.I.

**NOTES**

- DRAWINGS SHALL NOT BE SCALED.
- DIMENSIONS SHOWN ARE BASED ON THE ORIGINAL STRUCTURE PLANS.
- PROTECTIVE SURFACE TREATMENT SHALL BE APPLIED TO THE ENTIRE TOP SURFACE OF THE NEW CONCRETE OVERLAY.
- SEAL OVERLAY CONSTRUCTION JOINTS ACCORDING TO SECTION 502.3.13.1 OF THE STANDARD SPECIFICATIONS. COST INCIDENTAL TO BID ITEM "CONCRETE MASONRY OVERLAY DECKS".
- A MINIMUM OF 1-INCH OF CONCRETE SHALL BE REMOVED FROM THE ENTIRE BRIDGE DECK UNDER THE BID ITEM "CLEANING DECKS".
- THE AVERAGE OVERLAY THICKNESS IS BASED ON THE MINIMUM OVERLAY THICKNESS PLUS 3/4-INCH TO ACCOUNT FOR VARIATIONS IN THE DECK SURFACE.
- PREPARATION DECKS TYPE 1, PREPARATION DECKS TYPE 2, AND FULL-DEPTH DECK REPAIR AREAS ARE BASED ON THE PLANS AND AS DETERMINED BY THE ENGINEER. DECK PREPARATION AND FULL-DEPTH DECK REPAIRS SHALL BE FILLED WITH "CONCRETE MASONRY OVERLAY DECKS".
- ANY EXCAVATION REQUIRED TO COMPLETE THE OVERLAY OR JOINT REPAIRS AT THE ABUTMENTS TO BE CONSIDERED INCIDENTAL TO THE BID ITEM "CONCRETE MASONRY OVERLAY DECKS".
- PROFILE GRADE LINE SHALL BE DETERMINED IN THE FIELD BASED ON A MINIMUM OVERLAY THICKNESS OF 1 1/2" PLACED ABOVE THE DECK SURFACE AFTER SURFACE PREPARATION. EXPECTED AVERAGE OVERLAY THICKNESS IS 2" (OR AS GIVEN ON THE PLANS). IF EXPECTED AVERAGE OVERLAY THICKNESS IS EXCEEDED BY MORE THAN 3/4", CONTACT THE STRUCTURES DESIGN SECTION.
- DRAINS REMOVED OR CLOSED IS INCIDENTAL TO THE BID ITEM "CONCRETE MASONRY OVERLAY DECKS".

**DESIGNER NOTES**

- PLAN VIEW APPLICABLE TO ALL OVERLAY METHODS AND DECK REPAIRS WITHOUT OVERLAYS.
- FOR CROSS SECTIONS NOT IN SUPERELEVATION TRANSITIONS, THE PREFERRED MINIMUM SLOPE IS 2%.
- PROVIDE AN AVERAGE OVERLAY THICKNESS ON THE PLANS. THE AVERAGE OVERLAY THICKNESS IS THE MINIMUM OVERLAY THICKNESS PLUS 3/4" TO ACCOUNT FOR VARIATIONS IN THE DECK SURFACE. CHANGES IN CROSS-SLOPE INCREASE THE AVERAGE OVERLAY THICKNESS. QUANTITIES ARE BASED ON THE AVERAGE OVERLAY THICKNESS.
- DO NOT PROVIDE A PROFILE GRADE LINE ON THE PLANS.
- DO NOT INCLUDE BID ITEM "SAWING PAVEMENT DECK PREPARATION AREAS" FOR DECK PREPARATION.
- \* REMOVAL OF 1" OF EXISTING DECK UNDER BID ITEM "CLEANING DECKS" IS NOT INTENDED FOR PREVIOUSLY OVERLAID DECKS. EXISTING CONCRETE COVER (1" MIN.) SHALL BE MAINTAINED AND CONSIDERED WHEN DETERMINING CONCRETE REMOVALS. INCLUDE THE BID ITEM "CLEANING DECKS TO REAPPLY CONCRETE MASONRY OVERLAY" WHEN REMOVING EXISTING OVERLAY.
- † PROVIDE (IF AVAILABLE) THE MOST CURRENT DECK CONDITION ASSESSMENT SURVEY ON PLANS. INCLUDE SURVEY TYPE AND DATE COMPLETED. THERMOGRAPHY DATA CAN BE FOUND IN HSS WITHIN GENERAL INVENTORY/FILE/INSPECTION/DATE/INSPECTION SPECIAL REPORT. DECK CONDITION ASSESSMENT SURVEY DATES CAN BE FOUND WITHIN INSPECTION/HISTORY UNDER THE "DEVAL" ACTIVITY TYPE.
- JOINT REPAIR AREAS SHOULD NOT BE INCLUDED IN DECK REPAIR AREAS OR OVERLAY QUANTITIES. SEE STANDARD 40.04.
- INCLUDE THE BID ITEM "ADJUSTING FLOOR DRAINS" WHEN DRAINS ARE TO BE RAISED.
- \* RESTRICTIONS ON REMOVAL ITEMS SHALL BE PLACED ON THE PLANS TO PREVENT DAMAGE TO REINFORCING STEEL.
- ▲ OVERLAY LIMIT SHOULD BE OFFSET FROM EXISTING OPEN STEEL RAILING FOR IMPROVED ACCESS FOR DECK REMOVAL AND OVERLAY PLACEMENT. OVERLAY LIMITS FOR PREVIOUSLY OVERLAID DECKS SHALL BE BASED ON THE EXISTING OVERLAY LIMITS.
- OPTIONAL CONSTRUCTION JOINTS SHALL BE LOCATED AT CROWN POINTS AND OTHER GRADE BREAK LOCATIONS. COORDINATE STAGING TO AVOID GRADE BREAKS WITHIN A GIVEN STAGE, WHICH WILL REQUIRE SEPARATE OVERLAY POURS.

**CONCRETE OVERLAY**



APPROVED: *Laura Shadewald* DATE: 7-22