



Wisconsin Department of Transportation

January 29, 2024

**Division of Transportation Systems
Development**

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

**Proposal #16: 3190-11-70
Springfield to Burlington
STH 120 to STH 11
STH 36
Walworth County**

Letting of February 13, 2024

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
43	Backfill Slurry, Item SPV.0035.01

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01
PROJECT ID 3190-11-70
January 29, 2024

Special Provisions

43. Backfill Slurry, Item SPV.0035.01

Replace entire article language with the following:

A Description

This special provision describes furnishing and placing backfill slurry for, but not limited to, removing and abandoning utility pipes and structures, installation of storm sewer, sanitary sewer, and water pipes and structures, and exposing existing utility items as shown on the plans. Conform to 209 of the standard specs except as follows.

B Materials

Replace 209.2.2 of the standard spec with the following:

- (1) Use well graded fine and coarse aggregate conforming to the standard combined aggregate gradation specified in table 501-4. Weigh aggregates at a batch plant suitable for batching concrete masonry. Mix and deliver to the project site using a truck mixer. Add enough water meeting the requirements of 501.2.6 of the standard specs to enable the mixture to flow readily.
- (2) Backfill Slurry is considered a class III concrete mix. Follow the procedure in 716.2.2 of the standard spec for mix design certification and submittal.

C Construction

Replace 209.3 of the standard specs with the following:

Prior to placement of backfill slurry provide for positive drainage of the area to be backfilled. Discharge from the truck in a manner to prevent segregation. Consolidation or compaction effort will not be required. Twelve hours shall elapse before paving over the backfill.

D Measurement

Replace 209.4 of the standard spec with the following:

The department will measure Backfill Slurry in volume by the cubic yard of material placed acceptably completed. Such volume shall be computed from actual measurements of the dimensions of the area to be backfilled. In irregular or inaccessible areas, the engineer may allow volume to be determined by other appropriate methods.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0035.01	Backfill Slurry	CY

Payment is full compensation conforming to 209.5.(2) and 209.5.(5) of the standard specs.

END OF ADDENDUM