



Curb Ramp Post Construction Compliance Report

Send a completed copy of this report to the WisDOT Region Bike/Ped. Coordinator for project.

Project ID		Project Name		Region	
Highway/Road			Intersecting Highway/Road		Curb Ramp ID
Date	Inspected By (Print)			Phone	Email

Ramp Location		Location in Intersection (i.e. quadrant)				Curb Ramp Type	
<input type="checkbox"/> Intersection	<input type="checkbox"/> Mid-block	<input type="checkbox"/> N	<input type="checkbox"/> E	<input type="checkbox"/> NW	<input type="checkbox"/> NE	<input type="checkbox"/> Diagonal	<input type="checkbox"/> Parallel
		<input type="checkbox"/> S	<input type="checkbox"/> W	<input type="checkbox"/> SW	<input type="checkbox"/> SE	<input type="checkbox"/> Perpendicular	<input type="checkbox"/> Other

Describe Ramp Location

Curb Ramp Attributes	Ramp Location 1	Ramp Location 2	Ramp Location 3	Ramp Location 4
Ramp Width (48" minimum)				
Running Slope (8.33% maximum)				
Cross Slope (2% maximum)				
Flare Slope - Left (10% maximum)				
Flare Slope - Right (10% maximum)				
Rollover (11% maximum)				

Level Landing Attributes

Level Landing Provided	Width (48" minimum)	Depth (48" minimum)	Cross Slope (2% maximum - both directions)
<input type="checkbox"/> Yes <input type="checkbox"/> No			

Detectable Warning Field

Depth (24" minimum)	Detectable Warning Spans Ramp Width	Radial Panels	Warning Field Color
	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yellow <input type="checkbox"/> White <input type="checkbox"/> Patina

Transition Details

Lip Present (> 1/4 inch)	Gutter Flowline Slope at Ramp (2% maximum)	Gutter Counter Slope (4% maximum)
<input type="checkbox"/> Yes <input type="checkbox"/> No		

Comments

Inspector's Signature	Date
-----------------------	------