

*Driveway and Sidewalk Ramps Type Z***References:**

Guide for the Geometric Design of Driveways, NCHRP Report 659, Transportation Research Board
[FDM 11-25-48](#) Driveways

Bid items associated with this drawing:

<u>ITEM NUMBER</u>	<u>DESCRIPTION</u>	<u>UNIT</u>
305.0120	Base Aggregate Dense 1 1/4-inch	Ton
602.0810	Concrete Driveway 6-inch	SY
602.0860	HES Concrete Driveway 6-inch	SY
602.0405	Concrete Sidewalk 4-inch.....	SF

Standardized Special Provisions associated with this drawing:

<u>STSP NUMBER</u>	<u>TITLE</u>
NONE	

Other SDDs associated with this drawing:

SDD 9A11	Driveway and Sidewalk Ramps Types X & Y
SDD 9A13	Driveways with Curb and Gutter Returns

Design Notes:

Consult with Region Access Management Staff prior to matching existing width if less than 16' or greater than 35'.

Sidewalk within the limits of the driveway shall be measured and paid for as Concrete Driveway 6-inch.

Comply with ADA and PROWAG requirements for sidewalk cross slopes (1.5 percent for WisDOT projects).

Comply with ADA and PROWAG 8.33 percent maximum sidewalk ramp profiles when placing existing and proposed sidewalks next to driveways.

Label driveway widths and locations on the Plan and Profile Sheets.

Label elevations, offsets and percent grades on Cross Sections.

Contact Person:

John Jenkins (608) 267-6785