



Wisconsin Department of Transportation

March 8, 2018

Division of Transportation Systems Development

Bureau of Project Development
4802 Sheboygan Avenue, Rm 601
P O Box 7916
Madison, WI 53707-7916

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

**Proposal #26: 4880-01-70 WISC 2018 155
CTH D (Main Street)
West Village Limits – Beech St
CTH D
Ozaukee County**

Letting of March 13, 2018

This is Addendum No. 01, which provides for the following:

Special Provisions:

Added Special Provisions	
Article No.	Description
40	Lighting Control Cabinets 120/240 30-Inch, Item 659.2130

Other

Article 15. QMP Base Aggregate, Item SPV.0105.001 is missing from the special provisions table of contents, but is located on pages 23 – 31 of the special provisions

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01

4880-01-70

March 8, 2018

Special Provisions

40. Lighting Control Cabinets 120/240 30-Inch, Item 659.2130.

Add the following to standard spec 659.2:

(2) Furnish contactors for luminaire and lighting receptacle conductors alike.

Add the following to standard spec 659.3.5:

(2) Luminaire and lighting receptacle conductors shall be photocell controlled.

END OF ADDENDUM