



Wisconsin Department of Transportation

January 11, 2021

Division of Transportation Systems Development

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

Proposal #14: 6998-05-05, WISC 2021 082
City Waupun, S Madison Street
Doty Street To E Lincoln Street
Local Street
Dodge County

6998-05-06
City Waupun, S Madison Street
Doty Street To E Lincoln Street
Local Street
Dodge County

Letting of January 12, 2021

This is Addendum No. 02, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
35	Water Service Corp, Stop, Box, Saddle and Union 1 1/4-Inch, Item SPV.0060.21

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 02
6998-05-05, 6998-05-06
January 11, 2021

Special Provisions

35. Water Service Corp, Stop, Box, Saddle and Union 1 1/4-Inch, Item SPV.0060.21.

*Replace entire section titled **B.2 Water Service Corp, Stop, Box, Saddle and Union** with the following:*

B.2 Water Service Corp, Stop, Box, Saddle and Union

All water services, unless noted otherwise on the plans, shall be 1 1/4-inch nominal diameter.

Service line connection to PVC mainline pipe shall be made using a compression fitting (outlet) and a "CC" thread (inlet) saddle type connection as manufactured by Mueller, A.Y. McDonald or approved equal. Service connections shall be rated for 250 psi, have a conductive compression connection, have a coated ductile iron body, 304 stainless steel strap, nitrile O-ring gasket, and meet all applicable parts of ANSI/AWWA C800. A simple threaded connection shall not be acceptable.

Curb stops shall be manufactured by Mueller, A.Y. McDonald or approved equal, with threaded connections. Curb stops shall be rated for 250 psi, have a conductive compression connection, have a Minneapolis top thread, and conform to AWWA C800.

Curb stop box shall be Mueller, A.Y. McDonald or approved equal, with Minneapolis pattern, 7-foot bury, 1 1/4- inch upper pentagon nut opening without stationary rod.

All curb stops shall include tracer wire and a tracer wire terminal box installed next to the curb stop box flush with the finished ground elevation (incidental to curb stop). Tracer wire shall be No 12 gauge, ASTM D1248, solid insulated copper wire rated for wet conditions. All tracer wire terminal boxes shall be Bingham and Taylor, 2 1/2-inch diameter shaft, Model P200NFG. Lids shall be marked "Water" for water utilities. Eighteen inches of extra wire shall be provided at all terminations.

END OF ADDENDUM