



Wisconsin Department of Transportation

January 21, 2021

**Division of Transportation Systems
Development**

Bureau of Project Development
4822 Madison Yards Way, 4th Floor South
Madison, WI 53705

Telephone: (608) 266-1631
Facsimile (FAX): (608) 266-8459

NOTICE TO ALL CONTRACTORS:

<p>Proposal #08: 5991-07-43, WISC 2021 138 C of La Crosse, Gillette Street Caledonia St to George St (STH 35) Local Street La Crosse County</p>	<p>5991-07-44 C of La Crosse, Gillette Street Caledonia St to George St (STH 35) Local Street La Crosse County</p>
--	---

Letting of February 9, 2021

This is Addendum No. 01, which provides for the following:

Special Provisions:

Revised Special Provisions	
Article No.	Description
32	Replace Hydrant, Item SPV.0060.15

The responsibility for notifying potential subcontractors and suppliers of these changes remains with the prime contractor.

Sincerely,

Mike Coleman

Proposal Development Specialist
Proposal Management Section

ADDENDUM NO. 01

5991-07-43/44

January 21, 2021

Special Provisions

32. Replace Hydrant, Item SPV.0060.15

Replace entire article language with the following:

A Description

This work consists of salvaging existing hydrant, and installing City supplied fire hydrants including excavating, setting new hydrants, stone drain material, joint restraint, connection of hydrant to hydrant lead including fittings, backfill and compaction, all according to the requirements of the plans, the standard specifications and the City of La Crosse Standard Specifications and Procedures for Water Construction.

B Materials

Hydrant will be supplied by the City of La Crosse.

All water main materials shall conform to the AWWA Specifications latest designation specifications.

Mechanical joint restraint shall be installed at the hydrant and included in the cost bid for hydrants. Joint restraints shall be Meg A Lug wedge action type joint restraints manufactured by EBBA Iron Sales or an approved equal.

C Construction

Replace hydrant shall be installed and tested accordance with City of La Crosse Standard Specifications and Procedures. Hydrants must be inspected before backfill.

Existing hydrant being replaced is to be salvaged for City of La Crosse. Coordinate pickup from maintenance facility with Mark Graff, 608-789-7384 or by email graffm@cityoflacrosse.org.

D Measurement

The department will measure Replace Hydrant, by each hydrant removed, installed and tested, acceptably completed.

E Payment

The department will pay for measured quantities at the contract unit price under the following bid item:

ITEM NUMBER	DESCRIPTION	UNIT
SPV.0060.15	Replace Hydrant	Each

Payment is full compensation for all work to replace hydrant and materials including back filling, mechanical joints, and adjustment of hydrant elevations to meet minimum height above sidewalk, pavement, or finished grades within the work area.

END OF ADDENDUM